

Date	No.	Question	Response
5/14/09	1	Will there be area within close proximity of the project for:	See Below
		a. Office trailer	There is no office space available on the entire campus. Former housekeeping and storage closet spaces are available for contractors use but these are extremely small (approximately 50 square feet). If the contractor wishes to use such a space, one closet will be made available for contractors use.
		b. Dumpster	A location for a dumpster will be provided in the south parking lot, south side of Bldg 1D.
		c. Material staging	A 4'X20' section of the mechanical room to the west of the pharmacy on the 1st floor will be available for material staging. Contractor will need to schedule delivery of the air handler in such a manner that the unit is set on the roof the same day it arrives at the site. On site storage of the air handler will not be provided.
	2	Will we be able to use the Hospital restrooms	Yes. The restrooms to the south of the mechanical room on the first floor will be available for contractor use. Contractor will be expected to practice good housekeeping or lose the privilege.
	3	Will we be required to create a negative air condition during demolition?	Yes. As indicated in Section 01 00 00 of the General Requirements in the Specifications and as defined in the ICRA..
	4	What is the closest exit for removing demo material	Contractor will be limited to use of stairwell and one elevator for use. Contractors designated stairwell is the one on the southwest corner of the campus in Building 1D. Use of stairwell by contractor will not be limited. Contractor's elevator will be one of the two "Blue Elevators" in Building 1D. Use of the elevator will be limited to after hours only (anytime other than 7:00 AM to 5:00 PM on Monday through Friday).
	5	Can we stage a crane in the parking lot on the south side	Yes. A crane can be staged in the parking lot to the south of Bldg 1D. The crane staging will be required to be completed on a Saturday or Sunday. Contractor will be required to deliver the air handler to the site on the same day it is mounted on the roof.