

## Hazen Williams Coefficient, C

<u>Pipe Material</u>	<u>Design C</u>
PVC	150
Asbestos Cement	140
Welded Steel	100
Concrete	100
Cast Iron	100
Copper or Brass	130
Vitrified Clay	100
Corrugated Steel	60