## Hazen Williams Coefficient, C

Pipe Material	Design C
PVC	150
Asbestos Cement	140
Welded Steel	100
Concrete	100
Cast Iron	100
Copper or Brass	130
Vitrified Clay	100
Corrugated Steel	60