

Energy Savings Due to Wall/Window/Door Modifications

Modified Wall Element	Original U-Factor (From Tables)	Modified U-Factor (From Tables)	U-Factor Change	Wall or Element Area	Local Yearly Degree-Days (From Table 13)	Heat Savings Btu/yr
-----------------------------	--	--	--------------------	----------------------------	--	---------------------------

WINDOWS    1.13 - 0.58 = 0.55 x 30 ft<sup>2</sup> x 8382 x 24 = 3.32 x 10<sup>6</sup>

WALL    0.55 - 0.09 = 0.46 x 250 ft<sup>2</sup> x 8382 x 24 = 2.31 x 10<sup>7</sup>

Total = 2.65 x 10<sup>7</sup>

2.65 x 10<sup>7</sup> Btu/yr x .252 = 6.68 x 10<sup>6</sup> kg-cal/yr