

<b>CERTIFICATE OF COMPLIANCE</b>		(Part 4 of 4)	<b>OLTG-1C</b>
Project Name <i>Educational Version for Class Assignments Only</i>		Date 4/12/2011	
<b>ALLOWED AND INSTALLED OUTDOOR LIGHTING POWER</b>			
		Lighting Wattage Power Allowance	
A	Lighting power allowance for general hardscape (from OLTG-2C Page 1 of 3)	3,714	
B	Specific application lighting wattage allowance per unit length (from OLTG-2C Page 1 of 3)	2,400	
C	Specific application lighting wattage allowance for ornamental lighting (from OLTG-2C Page 1 of 3)	0	
D	Specific application lighting wattage allowance per application (from OLTG-2C Page 2 of 3)	595	
E	Specific application lighting wattage allowance per area (from OLTG-2C Page 2 of 3)	9,608	
F	Specific application lighting wattage allowance for ordinance requirements (from OLTG-2C Page 3 of 3)	108	
G	Total Allowed Wattage = Sum of rows A through F:	16,425	
H	Total installed watts (from Compliance Fixture Schedule, (from OLTG-2C Page 1 of 3)	16,375	
<b>Complies if wattage in row H is less than or equal to the wattages in row G</b>		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
<small>EnergyPro 5.1 by EnergySoft    User Number: 0001    RunCode: 2011-04-12T10:18:33    ID:    Page 4 of 10</small>			